

## Bibliographie

La bibliographie de la Partie 1 s'applique, avec les exceptions suivantes:

*Addition:*

ISO 4400, *Transmissions hydrauliques et pneumatiques – Connecteurs électriques à trois broches avec contact de sécurité – Caractéristiques et exigences*

ISO 6952, *Transmissions hydrauliques et pneumatiques – Connecteurs électriques à deux broches avec contact de sécurité – Caractéristiques et exigences*

---



# FINAL VERSION

# VERSION FINALE

---

**Automatic electrical controls –  
Part 2-8: Particular requirements for electrically operated water valves,  
including mechanical requirements**

**Dispositifs de commande électrique automatiques –  
Partie 2-8: Exigences particulières pour les électrovannes hydrauliques,  
y compris les exigences mécaniques**

An abstract background graphic featuring a complex network of thin, light gray lines that form a grid-like pattern with curved and intersecting lines, creating a sense of depth and technical precision.

This is a preview. [Click here to purchase the full publication.](#)

## CONTENTS

FOREWORD.....	4
1 Scope and normative references.....	7
2 Terms and definitions .....	9
3 General requirements .....	13
4 General notes on tests.....	13
5 Rating .....	13
6 Classification.....	13
7 Information.....	16
8 Protection against electric shock.....	17
9 Provision for protective earthing.....	18
10 Terminals and terminations.....	18
11 Constructional requirements .....	19
12 Moisture and dust resistance .....	19
13 Electric strength and insulation resistance.....	19
14 Heating .....	20
15 Manufacturing deviation and drift .....	21
16 Environmental stress .....	21
17 Endurance.....	22
18 Mechanical strength.....	23
19 Threaded parts and connections .....	26
20 Creepage distances, clearances and distances through insulation .....	26
21 Resistance to heat, fire and tracking .....	26
22 Resistance to corrosion .....	26
23 Electromagnetic compatibility (EMC) requirements – Emission.....	26
24 Components.....	26
25 Normal operation .....	26
26 Electromagnetic compatibility (EMC) requirements – Immunity.....	27
27 Abnormal operation .....	27
28 Guidance on the use of electronic disconnection .....	30
Annex H (normative) Requirements for electronic controls .....	31
Annex AA (informative) Relation between different flow coefficients .....	36
Annex BB (normative) Arrangement for the measurement of transient pressures caused by water valves.....	37
Annex CC (normative).....	40
Annex DD (normative) Torque .....	42
Annex EE (normative) Arrangement for the measurement of transient pressures caused by water valves with a declared pressure of up to and including 1,0 MPa (10 bar) .....	46
Bibliography .....	48
Figure BB.1 – Transient pressure measurement test rig schematic diagram .....	38
Figure DD.1 – Arrangements for carrying out the torque test.....	42

Figure EE.1 – Transient pressure measurement test rig for valves with a declared pressure of up to and including 1,0 MPa (10 bar) schematic diagram .....	46
Table 101 – Nominal size and thread size of end connections.....	16
Table 1 – Required information and methods of providing information .....	16
Table 102 – Torque test requirement for metal valves with internal threaded end-connections .....	25
Table 103 – Torque test requirement for metal valves with external threaded end-connections .....	25
Table 104 – Maximum winding temperature (for test of blocked output conditions and valves declared under Table 1, item 113) .....	28
Table CC.1 – Test requirements for valves intended for uses other than the control of water for tap and shower outlets .....	40
Table CC.2 – Test requirements for valves intended for the control of water for tap and shower outlets .....	41
Table DD.1 – Required torque for test .....	43
Table DD.2 – Tightening torque in newton metres (Nm) for bolts and screws for adaptors .....	45

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

### AUTOMATIC ELECTRICAL CONTROLS –

#### Part 2-8: Particular requirements for electrically operated water valves, including mechanical requirements

#### FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

**This consolidated version of the official IEC Standard and its amendment has been prepared for user convenience.**

**IEC 60730-2-8 edition 3.1 contains the third edition (2018-08) [documents 72/1077/CDV and 72/1120/RVC] and its amendment 1 (2021-10) [documents 72/1257/CDV and 72/1280/RVC].**

**This Final version does not show where the technical content is modified by amendment 1. A separate Redline version with all changes highlighted is available in this publication.**

International Standard IEC 60730-2-8 has been prepared by IEC technical committee 72: Automatic electrical controls.

This third edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- alignment of the text with IEC 60730-1 fifth edition (2013) including Amendment 1:2015;
- introduction of specific requirements for thermoplastic bodied valves for the control of water for tap and shower outlets (18.101.4.3 and Annex CC);
- removal of Subclause 18.102 Wetted material specifications.

Future standards in this series will carry the new general title as cited above. Titles of existing standards in this series will be updated at the time of the next edition.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

This Part 2-8 is intended to be used in conjunction with IEC 60730-1. It was established on the basis of the fifth edition of that standard (2013) including its Amendment 1 (2015) and Amendment 2 (2020). Consideration may be given to future editions of, or amendments to, IEC 60730-1.

This Part 2-8 supplements or modifies the corresponding clauses in IEC 60730-1 so as to convert that publication into the IEC standard: *Safety requirements for electrically operated water valves, including mechanical requirements*.

Where this part 2-8 states "addition", "modification" or "replacement", the relevant requirement, test specification or explanatory matter in part 1 should be adapted accordingly.

Where no change is necessary, part 2-8 indicates that the relevant clause or subclause applies.

In the development of a fully international standard, it has been necessary to take into consideration the differing requirements resulting from practical experience in various parts of the world and to recognize the variation in national electrical systems and wiring rules.

The "in some countries" notes regarding differing national practices are contained in the following elements:

- Table 1, footnotes ab and ac
- Table 13, footnote aa
- 1.1.4
- 16.2.1
- 18.101.3
- 27.2.3.1
- 27.101
- Table DD. 1, footnote a
- Table DD.2, footnote a

In this publication:

- 1) The following print types are used:
  - Requirements proper: in roman type.
  - *Test specifications: in italic type.*
  - Notes: in smaller roman type.
  - Defined terms: in **bold type**

- 2) Subclauses, notes, tables or figures which are additional to those in part 1 are numbered starting from 101, additional annexes are lettered AA, BB, etc.

The committee has decided that the contents of the base publication and its amendment will remain unchanged until the stability date indicated on the IEC web site under [webstore.iec.ch](http://webstore.iec.ch) in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

## AUTOMATIC ELECTRICAL CONTROLS –

### Part 2-8: Particular requirements for electrically operated water valves, including mechanical requirements

#### 1 Scope and normative references

This clause of Part 1 is applicable except as follows:

##### 1.1 Scope

###### *Replacement:*

This part of IEC 60730 applies to electrically operated water valves for use in, on or in association with equipment for household and similar use, including heating, air-conditioning and similar applications. The equipment can use electricity, gas, oil, solid fuel, solar thermal energy, etc., or a combination thereof.

NOTE 1 Throughout this document, the word "equipment" means "appliances and equipment."

This document is applicable to electrically operated water valves for building automation within the scope of ISO 16484.

This document also applies to automatic electrically operated water valves for equipment that can be used by the public, such as equipment intended to be used in shops, offices, hospitals, farms and commercial and industrial applications.

EXAMPLE 1: Electrically operated water valves for commercial catering, heating and air-conditioning equipment.

This document does not apply to electrically operated water valves intended exclusively for industrial process applications unless explicitly mentioned in the relevant equipment standard.

This document applies to electrically operated water valves powered by primary or secondary batteries, requirements for which are contained within the standard, including Annex V.

This document does not cover the prevention of contamination of drinking water as a result of contact with materials.

**1.1.1** This document applies to the inherent safety, to the operating values, operating times and operating sequences where such are associated with equipment safety, and to the testing of automatic electrical control devices used in, on or in association with, household and similar equipment.

This document contains requirements for electrical features of water valves and requirements for mechanical features of valves that affect their intended operation.

This document is also applicable to electrically operated water valves for appliances within the scope of the IEC 60335 series of standards.

This document does not apply to:

- electrically operated water valves of nominal connection size above DN 50;
- electrically operated water valves for admissible nominal pressure rating above 1,6 MPa;

- food dispensers;
- detergent dispensers;
- steam valves;
- electrically operated water valves designed exclusively for industrial applications.

Throughout this document, where it can be used unambiguously, the term:

- "valve" is used to denote an electrically operated water valve (including actuator and valve body assembly);
- "actuator" means "electrically operated mechanism or prime mover";
- "valve body" means "valve body assembly";
- "equipment" includes "appliance" and "control system".

**1.1.2** This document applies to electrically operated water valves, responsive to or controlling such characteristics as temperature, pressure, passage of time, humidity, light, electrostatic effects, flow, or liquid level, current, voltage, acceleration, or combinations thereof.

**1.1.3** This document also applies to actuators and to valve bodies which are designed to be fitted to each other.

**1.1.4** This document applies to individual valves, valves utilized as part of a system and valves mechanically integral with multi-functional controls having non-electrical outputs.

NOTE Attention is drawn to the fact that, in many countries, additional test requirements and by-laws have been established by the water authorities or companies.

**1.1.5** This document applies to AC or DC powered electrically operated water valves with a rated voltage not exceeding 690 V AC or 600 V DC.

**1.1.6** This document does not take into account the **response value** of an **automatic action** of a valve, if such a **response value** is dependent upon the method of mounting the valve in the equipment. Where a **response value** is of significant purpose for the protection of the **user**, or surroundings, the value defined in the appropriate equipment standard or as determined by the manufacturer shall apply.

**1.1.7** This document applies also to electrically operated water valves incorporating **electronic devices**, requirements for which are contained in Annex H.

**1.1.8** This document applies also to electrically operated water valves using NTC or PTC **thermistors**, requirements for which are contained in Annex J.

**1.1.9** This document applies to the electrical and **functional safety** of electrically operated water valves capable of receiving and responding to communications signals, including signals for power billing rate and demand response.

The signals can be transmitted to or received from external units being part of the valve (wired), or to and from external units which are not part of the valve (wireless) under test.

**1.1.10** This document does not address the integrity of the output signal to the network devices, such as interoperability with other devices unless it has been evaluated as part of the **control system**.